

Sharkey, John

From: Lloyd, Nolan [Nolan.Lloyd@state.co.us]
Sent: Tuesday, April 24, 2007 11:02 AM
To: Sharkey, John
Subject: RE: Colorado Well Construction Policy on Mechanical and Drive Shoe "Seals"

John,

We do not recognize a drive shoe or any type of mechanical seal as an acceptable seal. All seals must meet the annulus, depth, and grout requirements as written in Rule 10 of the Construction Rules 2 CCR 402-2 (2005).

Nolan W. Lloyd
Chief Well Inspector
Colorado Division of Water Resources
1313 Sherman St.
Rm 818
Denver, CO 80203

From: Sharkey, John [mailto:John.Sharkey@idwr.idaho.gov]
Sent: Tuesday, April 24, 2007 10:44 AM
To: Lloyd, Nolan
Subject: Colorado Well Construction Policy on Mechanical and Drive Shoe "Seals"